



Product Service

CERTIFICATE

No. Z2 109549 0003 Rev. 01

Holder of Certificate: **SOLYCO Solar AG**

Baseler Str. 60
12205 Berlin
GERMANY

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262110001-01

Valid until: 2028-09-04

Date, 2023-09-21

(Zhulin Zhang)



CERTIFICATE

No. Z2 109549 0003 Rev. 01

Model(s): AMPERE Solar Pro xxx TG (xxx=360-425, in steps of 5)
xxx is standing for rated output power at STC.

Parameters:

| | |
|----------------------|---|
| Safety Class: | ClassII |
| Max. System Voltage: | 1500V DC |
| Test Laboratory: | Yangzhou Opto-Electrical Product Testing Institute No.10 West Kaifa Road, Yangzhou, 225009 Jiangsu P.R.China |
| Construction: | Framed or Frameless, with Junction box, cable and connector. |
| Fire Safety Class: | Class C according to UL790 |

Tested according to:

- IEC 61215-1:2016
- IEC 61215-1-1:2016
- IEC 61215-2:2016
- IEC 61730-1:2016
- IEC 61730-2:2016